

13.04.050 Authority of inspectors.

Inspectors and other duly authorized employees of the town shall be permitted to enter upon all properties at reasonable times as necessary for the purpose of inspection, measurement, sampling, testing and repairing, or to terminate service on any of the water or wastewater mains or service lines both inside and outside the town limits. (Ord. 11-1991 (part)).

13.32.040 Pretreatment for grease removal.

A. Installation of Grease Interceptors. All commercial and industrial customers of the town's wastewater system having a probability of significant grease discharge in their wastewaters shall install grease interceptors. All new customers and customers whose use changes the EQR value of the particular use as a result of renovation, remodel, or otherwise, shall install grease interceptors. The utilities/public works department shall determine whether a specific customer has a probability of having significant amounts of grease in its wastewater based on an evaluation of the type of use or proposed use of the customer.

B. Existing Facilities. Any restaurant in existence at the time the ordinance codified in this section becomes effective shall be required to install and properly maintain a town-approved grease interceptor by April 1, 1999. []

C. Design Requirements for Grease Interceptors. The utilities/public works department shall establish minimum requirements and specifications for grease interceptors for restaurants within the town. Such requirements and specifications shall include the size and type of construction based on the plumbing fixtures within the restaurant, which requirements and specifications may be amended from time to time by the utilities/public works department. A copy of current requirements and specifications shall be kept by the utility/public works department and building department and shall be available upon request to the public.

D. Grease Interceptor Size. The minimum size of the interceptor shall be determined by the utilities/public works department. The utilities/public works department reserves the right to determine the size of the interceptor.

E. Location Requirements. All grease interceptors shall be located outside of improvements, except with the prior written approval of the utilities/public works department.

F. Installation Requirements. Prior to installation, the proposed design and location for a grease interceptor shall be submitted to the utilities/public works department for approval. The utilities/public works department may require information and documentation reasonably necessary to determine whether the grease interceptor will comply with this section.

G. Maintenance. The customer shall be responsible for regular cleaning and maintenance of the grease interceptor. Accumulated grease and grit shall be removed as solids and disposed of in a manner approved by the utilities/public works department, and that meets state and federal requirements. Unless otherwise approved in writing by the utilities/public works department, cleaning shall be required not less than once every two months for grease interceptors.

H. Record of Maintenance. The user of a grease interceptor shall maintain and display to the utilities/ public works department upon request, proof of adequate cleaning of the grease interceptors, including an adequate record of the date of each cleaning, and the volume of grease removed, or an estimate thereof.

I. Inspection. The utilities/public works department may make periodic inspections of grease interceptors to insure compliance. (Ord. 24-1998: Ord. 11-1991 (part)).

13.32.050 Manufacturing and industrial uses.

Manufacturers and industries are prohibited from using the town wastewater system unless they obtain a special permit from the town, the granting of which is discretionary, said permit defining the conditions, limitations, and restrictions, and the fees and charges determined by the board of trustees to be for the best interest of the town and its inhabitants. (Ord. 11-1991 (part)).

13.32.060 Usage increasing operating costs.

Each user which discharges any pollutants which cause an increase in the cost of managing the effluent or the sludge of the town's treatment works shall pay for such increased costs. (Ord. 11-1991 (part)).