


- NOTES:**
1. Pad to be a minimum of 6" thick.
 2. Primary and secondary compartment to be left as an open area.
 3. Conduits to be centered in openings as shown above.



Date	Revisions	Drawn By:
		Checked:
		Approved:
		Scale: Not to Scale

Concrete Pad Specification
for 45 - 750 KVA
Pad Mount Transformer

**NEW BERN
ELECTRIC
New Bern, N.C.**

Concrete Pad Specification 45 kVA to 750 kVA Padmount Transformer